

4/11/25, 10:52 AM

Gmail - FIRE SAFETY CERTIFICATE -Sant Nagpal Public School, located at Gole Building Chhattarpur Mandir Complex, Chh..



Sant Nagpal Public School,Chhattarpur <snpschhattarpur@gmail.com>

**FIRE SAFETY CERTIFICATE -Sant Nagpal Public School, located at Gole Building
Chhattarpur Mandir Complex, Chhattarpur,**

1 message

DFS DAK <dak.dfshq@gmail.com>

To: diredu@nic.in, "snpschhattarpur@gmail.com" <snpschhattarpur@gmail.com>

Cc: dohqfpw.dlfire@nic.in

Fri, Feb 14, 2025 at 4:07 PM

Sir,

I am directed to forward a letter as an attachment for subject cited above.

Thanks

HQ,DELHI FIRE SERVICE

Note:- Any Correspondence/Communication relate to Department-Delhi Fire Service shall be share on Mail id:- director.dlfire@delhi.gov.in

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No. F.6/DFS/MS/School/2025/SZ/103

Dated...03/02/2025

FIRE SAFETY CERTIFICATE

Certified that **Sant Nagpal Public School**, located at **Gole Building Chhattarpur Mandir Complex, Chhattarpur, New Delhi 110074** comprised of Two Blocks, basement, ground plus two upper floors & ground plus two upper floors (Both Blocks are interconnect at each level) owned/occupied by Sant Nagpal Public School was issued FSC by this department vide letter no. F6/DFS/MS/School/2022/SZ/202 dated 24/02/2022. The premises was re-inspected by officer concerned of this department on 24/01/2025 in presence of Ms. Manju and observed that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the 03/02/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/02/2025 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Sant Nagpal Public School, at Gole Building Chhattarpur Mandir Complex, Chhattarpur, New Delhi -110074
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL-/NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.